



Ahmedabad Municipal Corporation



SCM HEALTH DEPARTMENT

Sanitary Convenience Certificate

A Certificate for Sanitary Convenience is issued to the Manager / Secretary / Organiser of the Talkies / Theatre named.....A.E.S. - A.G. SCHOOL.....C ENGLISH.....

MEDIUM.).....Situating
at.....OPP. Dada Saheb Flat, University Road, Navrangpura.....For
the period of.....12.....months / Days i. e. from.....01/01/26.....200 to
.....31/12/26.....200

Date : 16 - 4 - 20026

"Issued Subject to NOC from other Concerned departments".

u.n. 1196/75
16/4/26 AS. 1000/-

Copy to :-

1. The manager/Secretary of the Theatre/organiser
2. The Commissioner of Police, Ahmedabad.

Rajendra
Manager

A.E.S. - A.G. School (English Medium)
(Formerly Known as S.H. Kharawala,
A.G. & L.D. Primary School)

CBSE Affiliation No. 430546 School Code :- 11593

Rajendra
Dy. Director

(S.W.M. West Zone)

Dy/Add. Medical officer of Health
Municipal Corporation Ahmedabad.


Zone SCM (WZ)

Suryadhye
i/c Principal

A.E.S. - A.G. School (English Medium)
CBSE Affiliation No. 430546 School Code No. 11593
Opp. Dada Saheb Flat, University Road,
Navrangpura, Ahmedabad-380009.



AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
(An ISO 9001: 2015 Accredited Laboratory)



Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

Lic No QAC/R91/4650

February 20, 2026.

To,
The Principal,
A.E.S. – A.G. School (English Medium)
Opp. Dada Saheb Flat, University Road
Navrangpura, Ahmedabad – 380009.

Dear Sir,

We have analyzed your water samples collected on Dt. 09-02-2026 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Ground Floor Primary Section	Ground Floor Pre Primary Section
		As per IS-10500-2012			
A.	Organoleptic and Physical Parameters				
1	Colour, Hazen units, Max	5	15	0.1	0.1
2	pH value	6.5-8.5	No relaxation	6.65	7.18
3	Turbidity, NTU, Max	1	5	0.74	0.65
4	Total dissolved solids, mg/l, Max	500	2000	96	208
B.	General Parameters				
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	30	40
2	Calcium (as Ca), mg/l, Max	75	200	8	8
3	Magnesium (as Mg), mg/l, Max	30	100	2.44	4.88
4	Chloride (as Cl), mg/l, Max	250	1000	20	40
5	Sulphate (as SO ₄) mg/l, Max	200	400	4.6	12.2
6	Total alkalinity (as CaCO ₃), mg/l, Max	200	600	40	120
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil	Nil
C.	Bacteriological Quality of Drinking Water				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected	Not Detected
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected	Not Detected

Remarks:

- The Central Laboratory, AMC, has collected the samples.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

Ranjana
Manager

A.E.S.-A.G. School (English Medium)
(Formerly Known as S.H.Kharawala,
A.G. & L.D. Primary School)
CBSE Affiliation No. 430546 School Code :- 11593

Dr. Hiren C. Mandalia
Dr. Hiren C. Mandalia
Scientist In-Charge

Principal
I/c Principal
A.E.S. - A.G. School (English Medium)
CBSE Affiliation No. 430546 School Code No. 11593
Opp. Dada Saheb Flat, University Road,
Navrangpura, Ahmedabad-380009.